



# Safety Technology International Ltd

Taylor House  
34 Sherwood Road  
Bromsgrove, Worcestershire  
B60 3DR England

Tel: +44 (0) 1527 520 999  
Fax: +44 (0)1527 501 999  
Email: info@sti-emea.com



## DECLARATION OF PERFORMANCE

No. ..DoP-2531-CPR-232.1737-rev0719..

1. Unique identification code of the product-type:....RP-RD2-01, RP-RF2-01, RP-RS2-01,...

.....RP-RF-01, RP-RS-01, RP-RS1-01.....

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):

.....L022 - SERIES 01 EN54 TERM LABEL 653a\_01 rev0719.....

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

.....Conventional Type A Re-settable Manual Call Point for Indoor Use, in accordance with EN54-11.....

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

.....SAFETY TECHNOLOGY INTERNATIONAL LTD

.....Taylor House, 34 Sherwood Road, Aston Fields Industrial Estate, Bromsgrove, Worcs. B60 3DR UK.....

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

.....n/a.....

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

.....System 1.....

7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:

.....DBI Certification A/S, Notified Body Number 2531.....

*(name and identification number of the notified body, if relevant)*

performed .....

under system .....System 1.....

*(description of the third party tasks as set out in Annex V)*

and issued .....2531-CPR-232.1737.....

[www.sti-emea.com](http://www.sti-emea.com)

We protect the things that protect you.

Safety Technology International Ltd. Company No: 05872791





# Safety Technology International Ltd

Taylor House  
34 Sherwood Road  
Bromsgrove, Worcestershire  
B60 3DR England

Tel: +44 (0) 1527 520 999  
Fax: +44 (0)1527 501 999  
Email: info@sti-emea.com

(certificate of constancy of performance, certificate of conformity of the factory production control, test/calculation reports – as relevant)

## 8. Declared performance

Notes to the table.

1. Column 1 shall contain the list of essential characteristics as determined in the harmonised technical specifications for the intended use or uses indicated in point 3 above.
2. For each essential characteristic listed in column 1 and in compliance with the requirements of Article 6, column 2 shall contain the declared performance, expressed by level or class, or in a description, related to the corresponding essential characteristics. The letters 'NPD' (No Performance Determined) shall be indicated where no performance is declared.
3. For each essential characteristic listed in column 1, column 3 shall contain:
  - (a) dated reference of the corresponding harmonised standard and, where relevant, the reference number of the Specific or Appropriate Technical Documentation used;
  - or
  - (b) dated reference of the corresponding European Assessment Document where available and reference number of the European Technical Assessment used.

Essential characteristics (see Note 1)	Performance (see Note 2)	Harmonised technical specification (see Note 3)
Nominal activation conditions / Sensitivity and Performance under fire conditions	<10s response time (EN54-11 clause 4.3.2, 4.4, 4.7.1, 4.7.4, 5.2, 5.3)	EN 54-11:2001 + A1:2005
Operational reliability	Pass (EN54-11 clause 4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 5.4, 5.5)	
Durability of operational reliability; temperature resistance	-10°C to +55°C (EN54-11 clause 5.7, 5.9)	
Durability of operational reliability; vibration resistance	Pass (EN54-11 clause 5.14 – 5.17)	
Durability of operational reliability; humidity resistance	Resistant (EN54-11 clause 5.10, 5.12)	
Durability of operational reliability; corrosion resistance	Resistant (EN54-11 clause 5.11, 5.13)	
Durability of operational reliability; electrical stability	3A, 12-24VDC (EN54-11 clause 5.6)	

9. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

.....Steve Hunt.....  
(name and function)

.....Managing Director.....

...STI Ltd, Bromsgrove, 04 July 2019.....  
(place and date of issue)

.....  
(signature)

