



Safety Technology International Ltd



EU DECLARATION OF CONFORMITY

The manufacturer of the products covered by this Declaration is:

Safety Technology International Ltd

Taylor House, 34 Sherwood Road, Bromsgrove, Worcestershire, B60 3DR, England.

This declaration of conformity is issued under the sole responsibility of the manufacturer. The Directives covered by this Declaration:

2014/35/EU Low Voltage directive, as amended

2015/863 RoHS directive, as amended

Object of this Declaration: **Universal Button Range**

- UB-1 Universal Button
- UB-2 2" Universal Button
- UB-1-PN Universal Pneumatic Button
- UB-2-PN 2" Universal Pneumatic Button
- UB-1-TF Universal Touch Free Button
- LT-1UL Latching/Timer Module



The object of the declaration described above is in conformity with the relevant Union harmonisation legislation.

Switch Rating UB-1, UB-2	Switch Rating UB-1-PN, UB-2-PN	Switch Rating UB-1-TF	Switch Rating LT-1UL
2x Form "C" contacts	Form "Z" contacts	Form "C" contact 30VDC, 1A	Form "C" contact (timer) 30VDC, 3A
125/250VAC, 10A; 30VDC, 6A	240VAC, 10A Timer range 2 to 60s	Switch input 12VDC Standby 15mA, Active 25mA	Switch input 12-24 VAC/DC 18mA
Message LED: 12-24VDC	Message LED: 12-30VAC/DC	Message LED: 12-24VDC	
Temp -40°C to +85°C	Temp -9°C to +49°C	Temp -20°C to +70°C	

The manufacturer hereby declares under his sole responsibility that the product(s) identified above meet the substance restrictions of RoHS: Pb (0.1%), Hg (0.01%), Cd (0.01%), Cr VI (0.1%), PBB (0.1%), PBDE (0.1%), DEHP (0.1%), BBP (0.1%), DBP (0.1%) and DIBP (0.1%).

The technical documentation required to demonstrate that the product(s) meet the requirements of this directive has been compiled and is available for inspection by the relevant enforcement authorities. Last two digits of the year that CE Marking was first affixed: **94**

Signed for and on behalf of the manufacturer by:

.....Steve Hunt.....
(name and function)

.....Managing Director.....

.....STI Ltd, Bromsgrove, 15 November 2017....
(place and date of issue)

.....
(signature)



ATTENTION

The attention of specifier, purchaser, installer, or user is drawn to special measures and limitations to use which must be observed when these product(s) are taken into service to maintain compliance with the above directives. Details of these special measures and limitations to use are available on request, and are also contained in the product manual.